

2025 Annual Water Quality Report of the Gloversville Board of Water Commissioners

This report is a requirement of the EPA and is distributed each year.

A note from the Gloversville Board of Water Commissioners: Commissioner Paul Hartman President, Commissioner Ronald Holly Jr. Vice President, Commissioner Timothy White, Commissioner Steven Cirillo, Commissioner James Mitchell. We are proud to distribute our Annual Water Quality Report (AWQR) to the citizens of Gloversville and the surrounding areas to whom we supply continuous, safe, sanitary and high-quality pure water.

IMPORTANT WATER CONSERVATION AND CONSUMER COST REDUCTION INFORMATION:

Although our system has an adequate amount of water to meet present and future demands, there are several reasons why it is important to conserve water:

" Saving water saves energy and some of the costs associated with both necessities of life.

" Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and

" Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

" Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.

" Turn off the tap when brushing your teeth.

" Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.

" Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

" Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak. We encourage all our residents to sign up for our free water monitoring portal by visiting gloversvillewater.my360-app.com. If you need further assistance in signing up for this portal you can contact our office at 518-773-4520.

Annual water usage and Financial Statement

The total amount of water delivered to the city during the year was 601,363,000 gallons; an average daily use of 1,647,569 gallons (based on 365 days in 2025). Of this amount, 62,693,910 gallons were used for manufacturing purposes, with an average daily use of 208,979 gallons (based on 300 working days in the year). The amount used for domestic and commercial consumption was 343,869,413 gallons, with an average daily use of 942,107 gallons (based on 365 days in 2025). During the year, the daily average use per capita for all public and domestic people was 62 gallons based on a population of 15,100.

The remaining amount was consumed in uses such as, hydrant flushing, hydrant testing, street cleaning, sewer flushing, firefighting, fire department training, ice skating rink, water leaks, industrial-commercial developments under construction and semi-annual testing of sprinkler systems by insurance carriers. city departments were furnished water for all purposes without charge. This includes city hall, all department of public works buildings, Gloversville Splash Pad, street and sewer flushing, fire department, parks department, and transit system.

Water Loss in Gallons

Leak this Size	Loss per Day	Loss per Month
•	120	3,600
•	360	10,800
•	693	20,790
•	1,200	36,000
•	1,920	57,600
•	3,096	92,880
•	4,296	128,980

Annual revenues for the year 2025 were \$3,152,396.12 and the average consumer cost of 1000 gallons of water was \$2.73.

State Inspection Findings:

1. All water entering the system from the filtration plant was of sanitary quality.
2. System Description

The Gloversville Water Works water delivery system is comprised of 3 basic components.

- Reservoirs and Watersheds
- Treatment
- Distribution and pure water storage.

Reservoirs and Watersheds	Total untreated water in storage	935,000,000 Gallons
----------------------------------	---	----------------------------

Treatment Plant

The treatment plant was built in 1939 and has been upgraded several times to maintain its capacity to treat and produce high quality potable water at the rate of 12 million gallons per day. Untreated water is allowed to flow to the treatment plant where it is treated and filtered. First, the water undergoes poly aluminum chloride coagulation to aid in the filtering process and is then treated with soda ash for pH control, sodium hexametaphosphate to protect the pipes and plumbing within the system, fluoride is added to improve oral health, and chlorine is added to sanitize the water before it enters the distribution system. The treatment plant operates the only State certified commercial bacteriological laboratory in Fulton, Montgomery, and Hamilton counties.

Pure and Treated Water Storage	Total Pure water in storage	4,552,000 Gallons
---------------------------------------	------------------------------------	--------------------------

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water sources include, Jackson Summit Reservoir, Cameron Reservoir and Dixon Pond, all located in the Town of Mayfield, Rice Reservoir and Port Reservoir located in the Town of Johnstown and Lake Edward Reservoir located in the Town of Bleeker.

Analytical Results

Our water has been tested for **27 inorganic compounds, 54 volatile organic compounds, nitrate, nitrite, 50 synthetic compounds, 6 radiological elements, lead and copper, disinfection by-products, PFOA and 1,4-Dioxane, and Absteos.** We also test our water daily for **pH, alkalinity, hardness, iron, color, and turbidity.** The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Therefore, some of the data, though representative of the water quality, is more than one year old. The table on page 3 depicts the compounds that were detected. Many of the test results were **NON-DETECTABLE.**

Contaminants:

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Unregulated Contaminant Monitoring 4 was conducted during 2024. This is a requirement of the 1996 Safe Drinking Water Act amendments. This monitoring provides a basis for future regulatory action to protect public health. The number in parentheses refers to the number of analytes measured for a total of 32 analytes. The breakdown of analytes is as follows: semi volatile organic chemicals (3), pesticides and pesticide manufacturing byproduct (9), metals (2), alcohols (3), cyanotoxin chemical contaminants (10), brominated halo acetic acid groups (3) and indicator compounds (2). There are no associated MCL's for these compounds currently, with the exception of Manganese. We have listed those compounds that were detected in the table of Detected Contaminants for Gloversville.

Information on Cryptosporidium

Cryptosporidium is a microbial pathogen found in a surface water and groundwater under the influence of surface water. Although filtration removes Cryptosporidium, the most commonly used filtration methods cannot guarantee 100 percent removal. During September 2017 through August 2019, as part of our sampling plan, 24 samples of our Raw collected was presumed positive for Cryptosporidium and was confirmed positive. Therefore, our monitoring indicates the presence of Cryptosporidium in our source water. Current test methods do not allow us to determine if the organism is dead or if they can cause disease. 23 additional source water samples did not show the symptoms of infection include, nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome illness. We encourage immuno-compromised individuals to consult their health care provider regarding appropriate precautions to take to avoid infection.

Information on Giardia

Giardia is a microbial pathogen present in varying concentrations in many surface waters and groundwater under the influence of surface water. Giardia is removed/inactivated through a combination of filtration and disinfection or by disinfection. During September 2017 through August 2019, as part of our sampling plan, 24 samples from our Raw Reservoir source water were collected and analyzed for Giardia cysts. Of these samples, 4 were confirmed positive for Giardia cysts. Therefore, our monitoring indicates the presence of Giardia in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Giardia may cause giardiasis, an intestinal illness. People exposed to Giardia may experience mild or severe diarrhea, or in some instances no symptoms at all. Fever is rarely present. Occasionally, some individuals will have chronic diarrhea over several weeks or a month, with significant weight loss. Giardiasis can be treated with anti-parasitic medication. Individuals with weakened immune systems should consult with their health care providers about what steps would best reduce their risks of becoming infected with Giardiasis. Individuals who think that they may have been exposed to Giardiasis should contact their health care providers immediately. The Giardia parasite is passed in the feces of an infected person or animal and may contaminate water or food. Person to person transmission may also occur in day care centers or other settings where handwashing practices are poor.

Testing was performed by JH Consulting Group, PO Box 705, Newtonville, NY 12128 using NYS DOH certified labs #10248, 11216, 10350 and 10917

Information on Fluoride Addition

Our system is one of many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.6 to 0.8 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires we monitor fluoride levels on a daily basis. During 2024, monitoring showed fluoride levels in your water were in the optimal range 100% of the time. None of the monitoring results showed fluoride levels that approach the 2.2 mg/l MCL for fluoride.

Information on Lead

Lead can cause serious health problems, especially for pregnant women and children 6 years and younger. Please read this notice closely to see what you can do to reduce lead in your drinking water. Health Effects of Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development. Sources of Lead is a common metal found in the environment. Drinking water is one possible source of lead exposure. The primary source of lead exposure for most children is lead-based paint. Other sources of lead exposure include lead-contaminated dust or soil, and some plumbing materials. Lead is found in some toys, some playground equipment, some children's metal jewelry, and some traditional pottery. Although most lead exposure occurs when people eat paint chips and inhale dust, or from contaminated soil, exposure to lead can come from lead in drinking water. Lead is rarely found in source water but enters tap water through corrosion of plumbing materials. Homes built before 1988 are more likely to have lead pipes or lead solder. However, new homes are also at risk: even legally "lead-free" plumbing may contain up to

0.25% lead on a weighted average. The most common is with brass or chrome-plated brass faucets and fixtures which can leach significant amounts of lead into the water, especially hot water. Exposure to lead is a significant health concern, especially for young children and infants whose growing bodies tend to absorb more lead than the average adult. Although your home's drinking water lead levels were below the action level, if you are concerned about lead exposure, parents should ask their health care providers about testing children for high levels of lead in the blood. Steps You Can Take to Reduce Your Exposure to Lead in Your Water

1. Run your water to flush out lead. Before drinking, flush your home's pipes for several minutes by running the tap, taking a shower, doing laundry, or doing a load of dishes. The amount of time to run the water will depend on whether your home has a lead service line or not, and the length of the lead service line. Residents should contact their water utility for recommendations about flushing times in their community.
2. Use cold water for cooking and preparing baby formula. Do not cook with or drink water from the hot water tap, lead dissolve more easily into hot water. Do not use water from the hot water tap to make baby formula.
3. Do not boil water to remove lead. Boiling water will not reduce lead.
4. Replace your plumbing fixtures if they are found to contain lead. Plumbing materials including brass faucets, fittings, and valves, including those advertised as "lead-free," may contribute lead to drinking water. The law previously allowed end-use brass fixtures, such as faucets, with up to 8 percent lead to be labeled as "lead free." As of January 4, 2014, end-use brass fixtures, such as faucets, fittings and valves, must meet the new "lead-free" definition of having no more than 0.25 percent lead on a weighted average. Visit the National Sanitation Foundation website at: http://www.nsf.org/newsroom_pdf/Lead_free_certification_marks.pdf to learn more about lead-containing plumbing fixtures and how to identify lead-free certification marks on new fixtures.
5. Use bottled water or use a water filter. If your home is served by a lead service line, and/or if lead containing plumbing materials are found to be in your home, you may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or visit <http://www.nsf.org/consumer-resources/what-is-nsf-certification/faucets-plumbingcertification/lead-older-homes>, for a consumer guide of approved water filters. Be sure to maintain and replace a filter device in accordance with the manufacturer's instructions to protect water quality. Any measure you take to reduce your exposure to lead should be continued until the lead source(s) has been minimized or eliminated. Should you test your water for lead? If lead-containing plumbing materials are identified in your home, you may want to consider testing your water for lead to determine how much lead is in your drinking water. To access information on service type/inventory for your home please visit our website at www.gloversvillewater.com and click on link "service type" to lookup your address. You can also call our office at 518-773-4520 to find out how to get your water tested for lead. Should your child be tested for lead? New York Public Health Law requires primary health care providers to screen each child for blood lead levels at one and two years of age as part of routine well-childcare. In addition, at each routine well-child visit, or at least annually if a child has not had routine well-child visits, primary health care providers assess each child who is at least six-months of age, but under six years of age, for high lead exposure. Each child found to be at risk for high lead exposure is screened or referred for lead screening. If your child has not had routine well-child visits (since the age of one year) and you are concerned about lead exposure to your child, contact your local health department or healthcare provider to find out how you can get your child tested for lead.

What Happened? What is Being Done?. The Gloversville Water Works remains committed to providing safe and potable drinking water to all our residents. Since 2017 we have been replacing lead line services throughout the city working under a NYS DOH grant to do so. We have received over 12 million in grant funding through the Bi-Partisan Infrastructure bill that was passed to continue to replace lead line services. Our goal is to completely eradicate lead service lines from our distribution system. Additional samples are being done to determine if a different corrosion control treatment process is necessary to prevent lead leaching from the pipes. For more information on lead in drinking water, contact your local health department New York State Department of Health, Herkimer District Office at 315-866-6879 or the New York State Department of Health directly by calling the toll-free number (within New York State) 1-800-458-1158, extension 27650, or out of state at (518) 402-7650, or by email at bpwsp@health.state.ny.us. For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, or call the National Lead Information Center at 1-800-424-LEAD.

Do I Need to Be Concerned About My Water?

Although our drinking water met or exceeded state and federal regulations it should be noted that some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Public Participation We encourage the public to become informed about their drinking water. The Gloversville Board of Water Commissioners meets on the third Tuesdays of each month, at 6:00 PM, unless otherwise noted, at their office at 67-73 South Main Street in Gloversville. The public is encouraged to attend.

For additional information concerning this report, please contact Anthony Mendetta, Superintendent, Gloversville Water Works, (518)-773-4518, Email at: amendetta@gloversvillewater.com, Safe Drinking Water Hotline, 1 800-426-4791 or NYSDOH Herkimer District Office (315)866-6879.

GLOVERSVILLE WATER WORKS TABLE OF DETECTED CONTAMINANTS Public Water Supply Identification Number NY1700018							
Contaminant	Violation Y/N	Date of Sample	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants							
Turbidity	N	8/15/25	024 ¹	NTU	N/A	TT=1.0 NTU	Soil runoff
			100%			TT= 95% samples < 0.3	
Inorganic Contaminants							
Chloride	N	7/15/25	7.31	mg/l	N/A	MCL=250	Naturally occurring or indicative of road salt contamination.
Chromium	N	7/15/25	5.1	µg/l	100	MCL=100	Discharge from steel and pulp mills; Erosion of natural deposits. Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis. Copper mg/l AL = 1.316 1.3 Corrosion of
Copper	N	7/9/25- 7/14/25	0.167 ²	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Range of copper concentrations			0.0049- 0.281				
Fluoride	N	7/15/25	0756 0.646-1.13	mg/l	N/A	2.2	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Lead	N	7/9/25- 7/14/25	7.9 ³	µg/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Range of lead concentrations			ND-30.8				
Manganese ⁸	N	7/15/25	3.69	µg/l	N/A	MCL=300	Naturally occurring; Indicative of landfill contamination.
Nickel	N	7/15/25	2.6	µg/l	N/A	N/A	Geology
Odor ⁴	N	7/15/25	2	units	N/A	MCL=3	Organic or inorganic pollutants originating from municipal and industrial waste discharges; natural sources.
pH	N	7/15/25	7.10	units	N/A	6.5-8.5	
Sodium ⁵	N	7/15/25	7.42	mg/l	N/A	N/A	Naturally occurring; Road salt; Water softeners; Animal waste
Stage 2 Disinfection Byproducts (quarterly samples)							
Haloacetic Acids (HAA5) average ⁶ (range of values)	N	2/18/25 5/5/25	32.075 7.2-53.4	µg/l	N/A	MCL=60	By-product of drinking water disinfection needed to kill harmful organisms.
TTHM [Total Trihalomethanes average ⁶ (range of values)]	N	8/18/25 11/18/25	65.825 16.7-102	µg/l	N/A	MCL=80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains organic matter.
Chlorine (continuous monitoring) average	N	daily testing	1.7 0.99-2.97	mg/l	MRDLG	MRDL	Used in the treatment and disinfection of drinking water
Range of chlorine residuals					4	4	
Total Organic Carbon ⁷ (monthly samples)							
Finished Water	N	2025	1.19-1.91	mg/l	N/A	TT	Organic material both natural and man made; decaying vegetation.
Unregulated Contaminant Monitoring Rule 5 Detected Contaminants (quarterly samples)							
Lithium	N/A	7/18/23	9.02	µg/l	N/A	N/A	Erosion of natural deposits
PFBA	N/A	7/18/23	1.8	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.

Gloversville Board of Water
Commissioners
67-73 S. Main St
Gloversville, New York 12078

Presorted
First Class Mail
US Postage
Paid
Gloversville,
NY
Permit # 47

